



Notes:

- INSULATION:** Jet fire seal clips should be insulated.
- CERTIFICATION:** Tested to J120 in accordance with HSE standard OTI 95 634 Lloyds Register of Shipping, Certificate No. SAS F000329, Blast over-pressure to 1.35 bar g, Lloyds Register of Shipping Certificate No. LWT 401087/1.
- CLIPPING:** Each seal is supplied with fitting instructions, adhesive and stainless steel worm drive clips to suit pipe and sleeve diameters. For diameters of 350mm and above 'double clipping' is required. The clipping length or cuff (B) is 30mm for single clips and 70mm for double clips.

Drawing Title:

STAINLESS STEEL SHROUDED PIPE
PENETRATION SEAL SYSTEM - J120



MCL UNITEX LTD
MCL House, Adams Close,
Heanor Gate Industrial Park,
Heanor, Derbyshire,
DE75 7SW
United Kingdom
Tel: +44 (0)1773 535365
Fax: +44 (0)1773 533478
Web: www.mclunitex.com

0	06/10/05	Drawing created	J.D.	N.R.T.	I.C.K.
Rev/Date Revision detail			Drn	Chkd	App'd
Drawing Number			PPS-0420		REV 0